

Product fiche

Delegated Regulation (EU) 811/2013

Seasonal space heating energy efficiency of heat pump

155 %

Temperature control

From fiche of temperature control

Class I = 1 %, Class II = 2 %, Class III = 1.5 %,
Class IV = 2 %, Class V = 3 %, Class VI = 4 %,
Class VII = 3.5 %, Class VIII = 5 %

+ 1.5 %

Supplementary boiler

From fiche of boiler

Seasonal space heating energy efficiency (in %)

(- - 155) x 0 = - - %

Solar contribution

From fiche of solar device

Collector size
(in m²)

Tank volume
(in m³)

Collector efficiency
(in %)


Tank rating
A⁺ = 0.95, A = 0.91,
B = 0.86, C = 0.83,
D-G = 0.81

(- x - + - x -) x 0.45 x (- / 100) x - = + - %

Seasonal space heating energy efficiency of package under average climate

157 %

Seasonal space heating energy efficiency class of package under average climate




Seasonal space heating energy efficiency under colder and warmer climate conditions

Colder: 157 - -1 = 158 % Warmer: 157 + -2 = 155 %

The energy efficiency of the package of products provided for in this fiche may not correspond to its actual energy efficiency once installed in a building, as the efficiency is influenced by further factors such as heat loss in the distribution system and the dimensioning of the products in relation to building size and characteristics.

Model placed on the Union market from 01/07/2014



EPREL registration number: 20754

<https://eprel.ec.europa.eu/qr/20754>

Supplier: Waterkotte GmbH (Manufacturer)

Website: <https://www.waterkotte.de>

Customer care service:

Name: Produktmanagement / Energielabel

Website: <https://www.waterkotte.de/>

Email: info@waterkotte.de

Phone: 0049232393760

Address:

Sophie-Opel-Straße 20
44803 Bochum
Germany